

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7271-0447:131 Page 1 of 1

CATEGORY: Ionization Smoke Detector

LISTEE: ESL/Sentrol, 12345 SW Leveton Drive, Tualatin, OR 97062
Contact: Gene Hukkanen (503) 691-7369

DESIGN: Models 712U, 722U, 732U and 742U ionization type detectors. Model 712U, 722U and 732U are two-wire detectors. Model 742U is four-wire detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as ionization type smoke detectors for use with Models 701E, 701U, 702E, 702U, 702RE and 702RU bases (CSFM Listing No. 7300-0447:133) and separately listed compatible fire alarm control units.

10-24-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 2, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager